



SWEETWATER AUTHORITY

505 GARRETT AVENUE
POST OFFICE BOX 2328
CHULA VISTA, CALIFORNIA 91912-2328
(619) 420-1413
FAX (619) 425-7469
<http://www.sweetwater.org>

GOVERNING BOARD

TERESA "TERRY" THOMAS, VICE CHAIR
JOSIE CALDERON-SCOTT
STEVE CASTANEDA
JOSÉ F. CERDA
RON MORRISON
JOSE PRECIADO
JESS VAN DEVENTER

JAMES L. SMYTH
GENERAL MANAGER

JENNIFER H. SABINE
ASSISTANT GENERAL MANAGER

April 27, 2017

ADDENDUM NO. 1

RE: Addendum to Request for Quotation #S2017-58

Bid Return Date – May 11, 2017

Please annotate the following changes to the Contract Documents for the subject project.
This addendum should be returned with your bid response.

- 1) Question: Do you require the Air Valves to be epoxy lined and coated?
Answer: Yes, please provide a quote for epoxy lined and coated air valves.

This addendum consists of one (1) page. All other terms and conditions remain unchanged.

If you have any questions, please contact me at 619-409-6872.

Sincerely,
SWEETWATER AUTHORITY

Gwen Balcom, C.P.M.